STATE OF MICHIGAN



DEPARTMENT OF NATURAL RESOURCES & ENVIRONMENT

LANSING



June 28, 2010

Mr. Tim Viola, Superintendent Chassell Township Wastewater Treatment Plant 22115 Seventh Street Chassell, Michigan 49916

Dear Mr. Viola:

SUBJECT: Chassell Township Wastewater Treatment Plant and Septage Waste Receiving Facility

Operating Plan Approval

Review of the Chassell Township septage waste receiving facility (SWRF) operating plan by the Department of Natural Resources and Environment (DNRE), Water Bureau, Drinking Water and Environmental Health Section, On-Site Wastewater Unit, is complete. The operating plan is approved and meets the requirements outlined in Section 11715b of Part 117, Septage Waste Servicers, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. The plan will be posted on the Septage Waste Program website at www.michigan.gov/septage.

The receiving facility must operate in accordance with the approved operating plan. If a change in operations, fee pricing or other conditions is anticipated, please file an amendment to the plan at least 30 days prior to the proposed date for implementation.

Thank you for your environmental stewardship and service to those with on-site septic systems in and around your community and the licensed septage waste businesses that service these systems. If you have any questions regarding this matter, please feel free to contact me by phone, fax, e-mail, or by mail at DNRE, Water Bureau, Drinking Water and Environmental Health Section, On-Site Wastewater Unit, P.O. Box 30273, Lansing, Michigan, 48909-7773.

Sincerely,

Matthew Campbell, Coordinator

Septage Waste Program On-Site Wastewater Unit

Drinking Water and Environmental Health Section

Water Bureau 517-335-4178

517-241-1328 FAX

campbellm4@michigan.gov

mc:ckp

cc: Ms. Lynn Madison, Western Upper Peninsula District Health Department, Houghton County

Mr. Steve Casey, DNRE

Mr. Chris Holmes, U.P. Engineers and Architects, Inc.

CHASSELL TOWNSHIP

SEPTAGE RECEIVING PLAN

CHASSELL TOWNSHIP SEPTAGE RECEIVING FACILITY OPERATING PLAN

Chassell Township has been and will continue to receive domestic septage waste at its lagoon facility to serve the residents of its service area as defined herein.

Receiving Facility Location

Chassell Township will accept septage at their wastewater treatment facility located along the Sturgeon River Road, Chassell Township, Michigan. Septage will be accepted for treatment into Lagoon 1 or Lagoon 2.

Hours of Operation

Chassell Township will accept septage Monday through Friday between the hours of 7:00 am to 3:30 pm and Saturday between 8:00am to 1:00 pm, for assistance call (906) 481-4000. In case of an emergency, arrangements may be made by calling the DPW Supervisor at (906) 370-8030.

Acceptable Categories of Septage

Chassell Township will accept the following categories of septage waste:

<u>Domestic Septage</u> – the septage pumped from home septic tanks, recreational vehicles (RV), cesspool, portable toilet, type III marine sanitation device, or similar storage or treatment works that receives only domestic sewage.

Fee Structure

The fee structure for septage discharge into the Chassell Township lagoon treatment facility is as follows:

 \$40.00 per 1,000 gallons or less of septage in a single load, charges for amounts in excess of the minimum 1,000 gallons per single load will be prorated per each additional hundred gallons at the rate of \$4.00 per hundred gallons.

Loading Capacity

Chassell Township has adequate hydraulic and organic treatment capacity to accept septage. The design receiving capacity of wastewater at the treatment facility is 250,000 gallons per day, with a current average daily flow of approximately 75,500 gallons per day. The design BOD loading is 200 mg/L or 416 lbs/day or 2,912 lbs/week. The anticipated average weekly flow of septage to be received is 5,700 gallons. Peak daily septage volume accepted is anticipated to be approximately 7,000 gallons per day. If septage accepted exceeds 5,000 gallons on any given day, septage will not be accepted on the following day (i.e. a one day rest period is required after receiving septage volume

greater than 5,000 gallons). Based on the design BOD loading, the lagoons have organic capacity to accept 22,000 gallons of septage per week, assuming a BOD concentration of 10,000 mg/L.

Service Area

The service area of the Chassell Township treatment facility is defined on the attached map. The service area as defined is restricted to the Chassell Township boundary.

Chassell Township may accept septage from areas within Houghton or Baraga County, outside the service area as defined above, on a case by case basis.

Other

Any hauler found disposing of any substance other than domestic septage may lose their right to dispose of septage at the Chassell Township lagoon receiving facility.

All haulers shall submit to random testing of their septage loads as requested by Chassell Township. Any problems encountered as a result of said sampling may result in the hauler losing their right to dispose of septage at the receiving facility.

Chassell Township reserves the right to limit/terminate the amount of gallons of septage accepted by the Chassell Township lagoon receiving facility for treatment and disposal by Chassell Township.

AFFIDAVIT OF PUBLICATION

IN THE MATTER OF NOTICE OF PROPOSED SEPTAGE RECEIVING FACILITY OPERATING PLAN CHASSELL TOWNSHIP

STATE OF MICHIGAN
COUNTY OF HOUGHTON SS

NOTICE OF PROPOSED SEPTAGE RECEIVING FACILITY OPERATING PLAN CHASSELL TOWNSHIP

Chassell Township has received, and will continue to receive, domestic septage waste on a limited basis in accordance with the developed operating plan

The operating plan includes and describes: the location, hours of operation, types of septage waste accepted, fee structure service area, and other conditions applicable to the receipt and acceptance of septage waste.

Copies of the proposed septage receiving facility operating plan have been submitted to all communities served by Chassell Township, and are available for review and written comments at the Chassell Township DPW office located at 22115 Seventh Street Chassell, MI 49916, between 8:00 a.m. to 3:00.p.m.; Monday through Friday.

Written comments concerning this plan should be submitted by June 21, 2010, to attention of:

Mr/Eim Viola Chassell Township DPW P.O.Box 438 Chassell MI 49916

YVONNE ROBILLARD

Being first duly sworn, says that he/she is the agent of the Publisher of The Daily Mining Gazette, a newspaper published in the English language for the dissemination of local or transmitted news and intelligence of a general character and legal news, which is a duly qualified newspaper, and that annexed hereto is a copy of a certain order taken from said newspaper in which the order was published on the following dates:

MAY 22, 2010

| 1 Monne Pobland |
|--|
| Agent of the Publisher of the Daily Mining Gazette |
| Subscribed and swom before me this 27th |
| Day of Mary A.D., 2010 |
| Catherine O'Cornell Rica Notary Public, Houghton County, Michigan |

Acting in and for the County of Houghton Michigan

CATHERINE O'CONNELL RICCI NOTARY PUBLIC, STATE OF MI COUNTY OF HOUGHTON MY COMMISSION EXPIRES: AUGUST 10, 2012

NOTICE OF PROPOSED SEPTAGE RECEIVING FACILITY OPERATING PLAN CHASSELL TOWNSHIP


Chassell Township has received, and will continue to receive, domestic septage waste on a limited basis in accordance with the developed operating plan.


The operating plan includes and describes: the location, hours of operation, types of septage waste accepted, fee structure, service area, and other conditions applicable to the receipt and acceptance of septage waste.

Copies of the proposed septage receiving facility operating plan have been submitted to all communities served by Chassell Township, and are available for review and written comments at the Chassell Township DPW office located at 22115 Seventh Street, Chassell, MI 49916, between 8:00 a.m. to 3:00 p.m., Monday through Friday.

Written comments concerning this plan should be submitted by June 21, 2010, to attention of:

Mr. Tim Viola Chassell Township DPW P.O. Box 438 Chassell, MI 49916






QUALITY MEAT PRODUCTS

MADE IN HANCOCK SINCE 1915

www.vollwerth.com






Chassell Township Septage Waste Receiving Facility Location



The aerial above shows the location of the Chassell Township lagoons where septage waste is disposed. Note that the lagoon gates are locked and a call must be made to the DPW prior to bringing septage for disposal.





NATURAL RESOURCES Department of Natural Resources and Environment

Septage Waste Receving Facility Checklist

Name of Septage Receiving Facility:

Chassell Township WWSL

Houghton County, Michigan

Address of Septage Waste Receiving Facility:

Sturgeon River Road

Chassell Township, Michigan

DEQ Reviewer: Matt Campbell

Page 1

Review Date: June 23, 2010

Facility Contact: Tim Viola, 22115 Seventh Street, Chassell, MI 49916

Telephone Number: 906-481-4000 Emergency Number: 906-370-8030

The following information must be submitted in the Operation Plan

in order to receive DNRE approval:

| Requirement | Yes | <u>No</u> | Comments Plat map provided showing the |
|--|-----|-----------|---|
| Location of septage RF. | X | | location. DNRE provided aerial photo of the facility. |
| 2. Hours of operation. | X | | M - F, 7 a.m. to 3:30 p.m. and Sat., 8 a.m. to 1 p.m. |
| 3. Categories of septage waste the RF will receive. | X | | Domestic septage including portable toilet wastes. |
| 4. If food establishment septage is accepted, does the RF required that the FES meets the 1:3 ratio mandated by law? (Not OP req't.) | | | Not applicable. FES is not accepted. |
| 5. *Fee structure charged to hauler. | X | | \$40/1,000 gallons |
| 6. *Service area (septage acceptance) description of RF defined in detail. | X | | Chassell Township only. |
| 7. Notice of proposed operation plan:a) Was it mailed to county HD and legislative body of each city, village and township located in whole or in part of the service area? | X | | Western Upper Peninsula Health Department contacted. |

DNRE

Septage Waste Receving Facility Checklist Chassell Township WWSL

Review Date: June 2, 2010

| 7. Notice of proposed op. plan, continued: b) "Was it public noticed in the local newspaper? X Copy provided. Not applicable. Chassell Township does not have a website. 8. Did the notice contain the following? a. Statement that the RF proposed to or is currently receiving and will continue to receive septage waste for treatment. b. Statement in the notice that the proposed operating plan is available for review during normal work hours. c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X See plan for details. | Requirement | <u>Yes</u> | <u>No</u> | Comments |
|--|---|------------|-----------|--|
| b) *Was it public noticed in the local newspaper? X Copy provided. Not applicable. Chassell Township does not have a website. 8. Did the notice contain the following? a. Statement that the RF proposed to or is currently receiving and will continue to receive septage waste for treatment. b. Statement in the notice that the proposed operating plan is available for review during normal work hours. c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. d. Receiving facility capacity. Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X Source Copy provided. Not applicable. Chassell Township does not have a website. | | | | |
| C) Was it posted on the facility website? 8. Did the notice contain the following? a. Statement that the RF proposed to or is currently receiving and will continue to receive septage waste for treatment. b. Statement in the notice that the proposed operating plan is available for review during normal work hours. c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailling of the notice. d. Receiving facility capacity. 1) Hydraulic capacity: X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 ibs/day. **III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | | | | |
| c) Was it posted on the facility website? 8. Did the notice contain the following? a. Statement that the RF proposed to or is currently receiving and will continue to receive septage waste for treatment. X b. Statement in the notice that the proposed operating plan is available for review during normal work hours. C. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailling of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | newspaper? | X | | Copy provided. |
| a. Statement that the RF proposed to or is currently receiving and will continue to receive septage waste for treatment. b. Statement in the notice that the proposed operating plan is available for review during normal work hours. c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. x d. Receiving facility capacity. Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | c) Was it posted on the facility website? | | | |
| is currently receiving and will continue to receive septage waste for treatment. b. Statement in the notice that the proposed operating plan is available for review during normal work hours. c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. II) Organic capacity: X *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | 8. Did the notice contain the following? | | | |
| receive septage waste for treatment. b. Statement in the notice that the proposed operating plan is available for review during normal work hours. c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. II) Hydraulic capacity: X Pesign BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | a. Statement that the RF proposed to or | | | |
| b. Statement in the notice that the proposed operating plan is available for review during normal work hours. c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. I) Hydraulic capacity: X Pesign BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X | | v | | |
| proposed operating plan is available for review during normal work hours. C. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | receive septage waste for treatment. | ^ | | |
| c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. I) Hydraulic capacity: X Pesign BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | | | | |
| c. A request for written comments on the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | | X | | |
| the proposed operation of the RF and the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | - | Λ. | | |
| the deadline for receipt of such comments, which shall not be less than 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) 9. Other conditions established for the | · · · · · · · · · · · · · · · · · · · | | | • |
| 30 days after publication, posting, or mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. II) Organic capacity: X Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | the deadline for receipt of such | | | |
| mailing of the notice. X Anticipating 5,700 gpd of septage w/ peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. I) Hydraulic capacity: X Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | | | | |
| d. Receiving facility capacity. peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | · · · · · · · · · · · · · · · · · · · | X | | |
| d. Receiving facility capacity. peak flows of 7,000 gpd. Design is 250,000 gpd. Current flow is 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) 7. Other conditions established for the | | - | | Anticipating 5.700 and of sentage w/ |
| I) Hydraulic capacity: X 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | d. Receiving facility capacity. | | | |
| I) Hydraulic capacity: X 75,500 gpd. Design BOD is 200 mg/L or 416 lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | | | | Design is 250,000 apd. Current flow is |
| II) Organic capacity: X lbs/day. *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | I) Hydraulic capacity: | X | | - |
| *III) Wet weather operation considerations (CSO & SSO) X 9. Other conditions established for the | | | | Design BOD is 200 mg/L or 416 |
| considerations (CSO & SSO) X 9. Other conditions established for the | II) Organic capacity: | Χ | | lbs/day. |
| 9. Other conditions established for the | • | | | |
| | considerations (CSO & SSO) | | X. | |
| | 9. Other conditions established for the | | | |
| | | X | | See plan for details. |